

**GOVERNMENT OF TRIPURA
OFFICE OF THE ASSISTANT ENGINEER
DRINKING WATER & SANITATION SUB-DIVISION,
TELIAMURA, KHOWAI TRIPURA.**

No. F.7(117)/AE/DWS/TLM/577.

Dated, 20/12/2022.

To
The Headmaster,
Ananda Marga High School,
Teliamura, Khowai, Tripura.

Sub: - Submission of chemical test report of water sample.


Sir,

With reference to the above letter, the chemical test reports of the water sample are sent here with after conduction necessary tests in the DWS Lab-Teliamura.

This is your kind information and necessary action.

Enclo:- As stated.

Yours faithfully,


Assistant Engineer
D.W.S, Sub-Division
Teliamura, Khowai.

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

No.F.7(117)/AE/DWS/TLM/ 577,

Date:20/12/2022

It is certified that an inspection team headed by Sri Haramohan Debbarma, (Assistant Engineer) from Drinking Water and Sanitation (DWS) inspected the **Ananda Marga High School, Shivbari, Teliamura, Tripura** on **20/12/2022** and found that the **Ananda Marga High School, Shivbari, Teliamura, Tripura** has safe drinking water facilities for the students and members and all staff of the institution and is maintaining the hygienic sanitation condition in the School building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 6(Six) Months.

Signature with Seal : _____

Name

: Sri Haramohan Debbarma

Designation

: Assistant Engineer.

DWS Sub-Division, Teliamura.

To

The Headmaster


Ananda Marga High School


Teliamura, Khowai, Tripura

**Sub-Divisional
Water Testing, Laboratory
DWS Sub-Division Teliamura
Khowai, Tripura.**

***WATER TESTING REPORT:-**

Sl. No.	Name of School	Source of Sample	Date of Test	Result (mg/l)							Remarks
				Temperature	PH	Turbidity (NTU)	Calcium	Magnesium	Hardness (mg/l)	Iron (mg/l)	
1	Ananda Margha High School, Shivbari Teliamura Tripura.	Bore Well attach with Aquaguard	20-12-22	31.17°C	6.8	0.0	17.14	29.18	140	0.016	<u>Permissible Limit</u> PH:-6.5-8.5 Turbidity:-5 NTU, Iron:-1.0 mg/l. Calcium- 75 mg/l. Magnesium-30 mg/l. Hardness-200 mg/l.


Sr. Reserch Assistant.
DWS Sub-Division Teliamura
Khowai Tripura.


Assistant Engineer
DWS Sub-Division Teliamura
Khowai Tripura.