



APPENDIX-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

No.F.7(117)/AE/DWS/TLM/38,

Date:09/04/2024

It is certified that an inspection team headed by Sri Haramohan Debbarma, (Assistant Engineer) from Drinking Water and Sanitation (DWS) inspected the **Ananda Marga High School, Shivbari, Teliamura, Tripura** on **06/04/2024** and found that the **Ananda Marga High School, Shivbari, Teliamura, Tripura** has safe drinking water facilities for the students and members and all staff of the institution and is maintaining the hygienic sanitation condition in the School building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 6(Six) Months.

Signature with Seal : _____

Name

: Sri Haramohan Debbarma

Designation

: Assistant Engineer.

DWS Sub-Division, Teliamura.

To
The Headmaster
Ananda Marga High School
Teliamura, Khowai, Tripura

**GOVERNMENT OF TRIPURA
OFFICE OF THE ASSISTANT ENGINEER
DRINKING WATER & SANITATION SUB-DIVISION,
TELIAMURA, KHOWAI TRIPURA.**

No. F.7(117)/AE/DWS/TLM/38

Dated, 09/04/2024.

✓
To
The Principal,
Ananda Marga High School,
Teliamura, Khowai, Tripura.

Sub: - Submission of chemical test report of water sample.

Dated:- Teliamura The 1st April, 2024.


Sir,

With reference to the above letter, the chemical test reports of the water sample are sent here with after conduction necessary tests in the DWS Lab-Teliamura.

This is your kind information and necessary action.

Yours faithfully,

Encl:- As stated.


Assistant Engineer
D.W.S, Sub-Division
Teliamura, Khowai
Tripura.

**Sub-Divisional
Water Testing, Laboratory
DWS Sub-Division Teliamura
Khowai, Tripura.**

***WATER TESTING REPORT:-**

Sl. No.	Name of School	Source of Sample	Date of Test	Result (mg/l)						Remarks	
				Temperature	PH	Turbidity (NTU)	Calcium	Magnesium	Hardness (mg/l)		Iron (mg/l)
1	Ananda Marga High School, Shivbari Teliamura Tripura.	Bore Well attach with Aquadguard	06-04-24	28.00°C	6.8	0.0	17.14	29.22	144	0.022	P. Limit PH:-6.5-8.5 Turbidity:-05, Iron:-1.0 mg/l. Calcium- 75-200 mg/l. Magnesium-30-150 mg/l. Hardness-200-600 mg/l.

Gopal Kumar

Sr. Reserch Assistant.
DWS Sub-Division Teliamura
Khowai Tripura.

Gopal Kumar
Assistant Engineer
Sub-Division
DWS Sub-Division Teliamura
Khowai
Tripura.